



NOTES:

1. Concrete 4,000 PSI at 28 days, minimum.
2. Steps are M.A. Industries #PS1-PF on 16" centers.
3. Grade adjustment rings available if required.
4. Sump Pits available where required.



7415 Diley Road  
Canal Winchester, OH 43110

Phone (614) 837-8444  
Fax (614) 837-1198

10" Water Meter Pit  
City of Columbus (OH)

Drawn by: CC

Scale: n/a

Date: 6/6/08